



Ohio Department of Commerce

77 South High Street • 23rd Floor
Columbus, Ohio 43215
(614) 466-3636 FAX (614) 644-8292
www.com.state.oh.us

Bob Taft
Governor

Lt. Governor Jennette Bradley
Director

April 9, 2003

Re: JOSAM Grease Recovery Devices (GRD's)

To Whom It May Concern:

The State of Ohio Plumbing Section has reviewed the "new technology" for GRD's and found that the JOSAM GI-2000 models 20gpm to 50 gpm meet the code requirements, Section 1003.3.4, for the State of Ohio and may be used in or out of the food preparation areas. The Josam EGLD Monitor probe is additionally approved as a means for monitoring the grease in existing "passive" traps to help control the maintenance of grease collection for businesses.

Sincerely,

A handwritten signature in black ink, appearing to read "Gary Krebs".

Gary Krebs
Plumbing Administrator

RECEIVED

APR - 9 2003

BUREAU OF
PLANS & SPECIFICATIONS